

**TYPE APPROVAL CERTIFICATE****This is to certify:****That the Electric Power Cable**

with type designation(s)

**MarineLine YZp & MarineLine+ & MarineFlex 0,6/1 kV,  
MarineLine YZafp 0,6/1 kV**

Issued to

**B.V. Twentsche Kabelfabriek  
Haaksbergen, Netherlands**

is found to comply with

**DNV GL rules for classification – Ships and offshore units  
DNV GL class programme DNVGL-CP-0399 – Type approval – Electric cables****Application :****General power and lighting.****Product(s) approved by this certificate is/are accepted for installation on all vessels classed  
by DNV GL.**

Type	Voltage class (kV)	Temp. class (°C)
<b>MarineLine YZp &amp; MarineLine+ &amp; MarineFlex 0,6/1 kV</b>	<b>0,6/1</b>	<b>90</b>
<b>MarineLine YZafp 0,6/1 kV</b>	<b>0,6/1</b>	<b>90</b>

This Certificate is valid until **2021-06-30**.Issued at **Høvik** on **2016-07-01**DNV GL local station: **Rotterdam**Approval Engineer: **Ivar Bull**for **DNV GL**

---

**Marit Laumann  
Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

## Product description

MarineLine YZp 0,6/1 kV,  
 MarineLine+ 0,6/1 kV,  
 MarineFlex 0,6/1 kV,  
 MarineLine YZafp 0,6/1 kV

### Construction:

Conductors: Plain or tinned stranded copper class 2, round or sector shaped or class 5 (MarineFlex)  
 Core insulation: XLPE  
 Filler: Non hygroscopic tape or Halogen free filler (MarineLine+ and MarineFlex)  
 Common screen: Aluminum PE foil (YZafp types only)  
 Outer sheath: SHF1

### MarineLine YZp 0,6/1 kV

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1 -37	1,5 2,5
1-5	4 - 300

### MarineLine+ YZp 0,6/1 kV

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1-5	1 - 300

### MarineFlex YZp 0,6/1 kV

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1-5	10 - 300

### MarineLine YZafp 0,6/1 kV:

No of cores:	Cross sectional area [mm <sup>2</sup> ]
1-37	1,5 2,5

## Application/Limitation

The requirements of SOLAS Amendments Chapter II-1, Part D, Reg. 45, 5.2 (provision to be taken to limit Fire Propagation along Bunches of Cables or Wires) are fulfilled without any additional measures.

## Type Approval documentation

Data sheets: TKF Catalogue Marine & Offshore cables 2012 dated March 2012  
 Test reports: TKF Rapport no. 301 dated 2004-10-12

## Tests carried out

Standard	Release	General description	Limitation
IEC 60092-350	2014-08	General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2014-04	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables.	

Job Id: **262.1-022237-1**  
Certificate No: **TAE000017J**

Standard	Release	General description	Limitation
IEC 60092-353	2011-08	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60332-1-2	2004-07	Tests on electric and optical fibre cables under fire conditions – Part 1-1: Test for vertical flame propagation for a single insulated wire or cable – Apparatus	Flame retardant small scale
IEC 60332-3-22	2009-02	Tests on electric and optical fibre cables under fire conditions – Part 3-22: Test for vertical flame spread of vertically-mounted bunched wires or cables – Category A	Bunch test Category A
IEC 60754-1	2011-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen
IEC 60754-2	2011-11	Test on gases evolved during combustion of materials from cables - Part 2: Determination of acidity (by pH measurement) and conductivity	Halogen free: pH > 4,3 Conductivity < 10µS/mm
IEC 60684-2	2003-05	Flexible insulating sleeving – Part 2: Methods of test.	Fluorine content < 0,1%
IEC 61034-1/2	2013-07 2013-09	Measurement of smoke density of cables burning under defined conditions – Test apparatus, procedure and requirements	Low smoke Light transmittance ≥60%

### Marking of product

TKF - Size - 0,6/1kV - MarineLine YZp – HALOGEN FREE - {batch nr}  
TKF - Size - 0,6/1kV - MarineLine+ YZp – HALOGEN FREE - {batch nr}  
TKF - Size - 0,6/1kV - MarineFlex YZp – HALOGEN FREE - {batch nr}  
TKF - Size - 0,6/1kV - MarineLine YZafp – HALOGEN FREE {batch nr}

### Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Assessment to be performed at least every second year.

END OF CERTIFICATE